

**ADDENDUM NO. 1**  
**SW DASH POINT ROAD & 47<sup>TH</sup> AVE SW COMPACT ROUNDABOUT**  
**CFW PROJECT 36217**

**ATTENTION ALL BIDDERS AND PLANHOLDERS:** You are hereby notified that the Bid and Contract Documents are amended as follows:

**A) CONTRACT DOCUMENTS**

**(1) Special Provisions Section 9-34.4:**

*The first paragraph of this section is revised as follows to change the reference from the "Utah Blend" to the "Swarco Series 3132":*

*"Surface-drop glass beads shall be the Swarco Series 3132 bead that has a Methacrylate compatible coupling agent approved by the material manufacturer."*

**B) BID QUESTION(S)**

*The following question(s) were sent to the City and the response is being provided here as it may be beneficial to all bidders:*

**(1) Is there a geotech report for this job?**

Yes, there is a geotech report, as well as an additional geotech memo regarding the soldier pile walls. They are being provided with this addendum.

**(2) Regarding bid item 25; plan sheet 12 detail A notes "Shotcrete facing color and finish shall match adjacent wall". This note appears to refer to the bid item 26 modular block wall appearing on sheet 11 and per special provision 6-13. Please confirm this is a correct interpretation.**

Yes, the color and finish of the shotcrete facing on the soldier pile wall should match the color and finish of the adjacent modular block wall.

**(3) A shotcrete finish that approximates the "concrete grey" color and typical broken face finish of a modular block is WSDOT 6-18.3(8) Alternative A. Is it appropriate to assume this finish, WSDOT Alternative A, is appropriate for this project? If not please, provide a picture or detailed description of the finish you would find acceptable.**

The intent of the shotcrete facing detail provided in the Advertised Bid Document drawings is to match the shotcrete facing color and finish to the Contractor selected adjacent modular block wall face jointing and texture as much as possible. The selected modular block wall must meet the requirements of the Modular Block Wall specifications in the Bid Documents. WSDOT 6018.3(8) Alternative A specifies a broom finish to secure a uniform surface texture, which would not match the adjacent modular block wall facing finish. The shotcrete facing color and finish shall match the color, joint spacing, and texture of the selected and constructed adjacent modular block to the maximum extent feasible.

**C) BID OPENING**

The bid opening date **has not** changed. All bidders are required to acknowledge receipt of this addendum on the Bid Form. Failure to do so may cause rejection of the bid.

**CITY OF FEDERAL WAY**

**Christine Mullen**

Christine J. Mullen, P.E.  
Senior Capital Engineer

City of Federal Way  
SW Dash Point Rd & 47<sup>th</sup> Ave SW Compact Roundabout

Addendum No. 1  
Page 1