



## **PARK TRAFFIC GATE ADDENDUM #1**

**Bid Due Date: Tuesday, March 3, 2020, 2 PM PST**

Addendum Date: February 25, 2020

Sent From: City of Federal Way, Owner

TO ALL PLANHOLDERS OF RECORD:

Notice is hereby given to all plan holders of record on this date that the following Addendum #1 shall answer questions raised about the 2" x 3.5" steel tubing called out for the curved sections of the traffic gates.

Since 2" x 3.5" tube is difficult to get and it was discovered that flat bars had been added to obtain this field measurement; the Parks Department is changing the curved sections to 2" x 4" steel tube with a maximum of .125 wall thickness on all curved portions of the gate.

Additional questions and ideas have been suggested about hinging the gate system with some modifications. Please submit bids as shown so everyone bids the same with the understanding the owner may elect to work with and modify the hinge system with the successful bidder.

**END OF ADDENDUM # 1**