



CITY HALL
33325 8th Avenue South • PO Box 9718
Federal Way, WA 98063-9718
(253) 835-7000
www.cityoffederalway.com

ADDENDUM NO. 02
STREET LIGHT INFILL
PROJECT #26775

ATTENTION ALL BIDDERS AND PLANHOLDERS: You are hereby notified that the Bid and Contract Documents are amended as follows:

A) BID QUESTIONS

The following question was sent to the City and the response is being provided here as it may be beneficial to all bidders:

What information should be included in the as-built survey?

Section 1-05.17 of the Special Provisions is the City's boilerplate specification for as-built survey and record drawings. The City's intent with regard to the as-built survey information is to document the location of the new features installed by this project. This could include light standards, junction boxes, and service cabinets, as well as location and depth of conduit borings. Existing features that were not modified as a part of this project do not need to be documented.

B) BID OPENING

The bid opening date **has not** changed. All bidders are required to acknowledge receipt of this addendum on page RFB-13 of this Bid Form. Failure to do so may cause rejection of the bid.

CITY OF FEDERAL WAY

Sincerely,

A handwritten signature in black ink that reads "Kathy Davis".

Kathy Davis, P.E., PTOE, RSP1
Senior Traffic Engineer

KD:kd

Enclosure

cc: Christine Mullen, P.E, Engineer Manager
Rick Perez, P.E., City Traffic Engineer

City of Federal Way
STREET LIGHT INFILL
Project #26775

1

Addendum No. 02